



QT11/2015

1st September 2015

To all prospective bidders,

Ref. No. QT11/2015 - Call for Quotations For the supply, delivery & installation of T8 Retrofit LED tubes of T8 LFL

CLARIFICATION 1

Reference is made to the above-mentioned call for quotations, for which the deadline for submission is on the 16th September, 2015 at 10:00am

Hereunder, please find a set of clarifications which are construed to form an integral part of the Call for Quotations Document.

CORRIGENDUM 1:

Article 14 - Technical Specifications and Appendix 1- Mandatory Requirements - T8 2 feet LED Retrofit of T8 & T8 4 feet LED Retrofit of T8 should read:

Colour temperature: 4000K - 4500K

Question 1: Can you kindly confirm that all LED retrofit tubes mentioned in the BOQ will be installed in the existing fittings?

Answer 1: Yes, all LED T8 fittings are to be installed on the existing tube holders.

All other documents, conditions and requirements, which are not superseded by this Clarification, remain in place.

Ms. Marlene Attard
DIRECTOR CORPORATE SERVICES
Malta Environment and Planning Authority