

QT22/2015

16th September, 2015

To all prospective bidders,

QT 22/2015 - Call for Quotations for the Supply and Delivery of Building Management System (BMS) Equipment, at MEPA, Floriana

CLARIFICATION NOTE 1

Reference is made to the above-mentioned call for quotations, for which the deadline for submission is on the 23^{rd} September, 2015 at 10:00am

Hereunder, please find a set of clarifications raised during the clarification meeting held on the 9^{th} September 2015.

Clarifications:

- 1. The interfacing between the Access Control and BMS, would be through software.
- 2. In order not to stall works, to be carried through other contracts, magnetic switches for the louvered windows, are to be forwarded as soon as possible since these will in turn have to be handed over to the louvers manufacturer/s.
- 3. Air Conditioners (A/C) would operate through FCUs (Fan Coil Unit).

All other quotation documents, conditions and requirements, which are not superseded by this Clarification, remain in place.

Ms. Marlene Attard
DIRECTOR CORPORATE SERVICES
Malta Environment and Planning Authority